

CERTIFICATE OF CONFORMITY

We hereby certify that the following item complies with the features listed below.

Item

Reference **SFERACO Fig. 357**
Description **RESILIENT SWING CHECK VALVE - from DN50 to DN300**

Main features

Body **EN-GJS-500-7**
Closure member **Disc EN GJS 500-7 + EPDM**
Connections **PN10-16 R.F. flanges according to EN 1092-2**
Face to face **According to EN 558 series 48 (DIN 3202 F6)**
Specifications **Full bore**

Operating conditions

Fluids **Drinking water, water distribution and watering**
PS **16 bar**
TS **-10°C to +80°C**

Standards

2014/68/EU Directive – Excluded according to article 4, §3

Quality management according to ISO 9001:2015

French water agreement A.C.S. N° 24 ACC LY 196

After Examination, the equipment was found not to be in the scope of the ATEX Directive 2014/34/EU. It has no own potential source of ignition.

Design according to EN 1074-3

Pressure tests according to EN 12266-1, Rate A; Coating according to DIN 30677

Product guarantee

2 years

Technical Director
St-Quentin-Fallavier, France, 2 May 2025



SYVECO
107 rue du Ruisseau
38070 Saint-Quentin-Fallavier - FRANCE
+33 474 948 650 | info@syveco.com
VAT: FR 92 487 897 449

www.syveco.com

Tél. +33 474 948 650 | info@syveco.com

107 rue du Ruisseau | 38070 Saint-Quentin-Fallavier | France

SAS au capital de 1 000 000 € | SIRET 487 897 449 00020 | APE 4669B | TVA INTRA. FR 92 487 897 449