

CERTIFICATE OF CONFORMITY

We hereby certify that the following item complies with the features listed below.

Item

Reference **SFERACO Fig. 1150**
Description **DUCTILE IRON BUTTERFLY VALVE WAFER - from DN32/40 to DN600**

Main features

Body **GGG50 rilsan coated**
Closure member **Disc CF8M up to DN100, GGG50 rilsan coated above**
Seat **EPDM**
Connections **Wafer type, Between flanges PN10/16 & ANSI 150 up to DN400, PN10 above**
Face to face **EN 558 series 20**
Specifications **ISO pad, Full crossing stem, Locking device up to DN200**

Operating conditions

Fluids **Cold and hot water, drinkable water**
PS **16 bar up to DN300, 10 bar above**
TS **-20°C to +110°C**

Standards

2014/68/EU Directive – Risk category III / Module H - Notified body : CE 0094
Quality management according to ISO 9001:2015
French water agreement A.C.S., Polish Water agreement PZH
After Examination, the equipment was found not to be in the scope of the ATEX Directive 2014/34/EU. It has no own potential source of ignition.
Bureau Veritas Type Approval Certificate, Safety integrity level certification SIL 2 according to IEC/EN 61508, SIL 3 capable following the installation.

Product guarantee

10 years

Technical Director
St-Quentin-Fallavier, France, 2 May 2025



SYVECO
107 rue du Ruisseau
38070 Saint-Quentin-Fallavier - FRANCE
+33 474 948 650 | info@syveco.com
VAT : FR 92 487 897 449

www.syveco.com

Tél. +33 474 948 650 | info@syveco.com
107 rue du Ruisseau | 38070 Saint-Quentin-Fallavier | France
SAS au capital de 1 000 000 € | SIRET 487 897 449 00020 | APE 4669B | TVA INTRA. FR 92 487 897 449